

List Figures

Figure 1.1	Monthly Average Daily Solar Radiation in Brunei Darussalam (2015–2016)	11
Figure 1.2	Annual Average Hourly Solar Radiation for 2015 and 2016	12
Figure 1.3	Rainfall Data in Bangar, Temburong District (2015 and 2016)	13
Figure 1.4	Overall Population in Temburong (2002–2016)	14
Figure 1.5	Share of Population in Temburong by Mukim	14
Figure 1.6	Bangar Town	15
Figure 1.7	Bangar Proposed Land Use	16
Figure 2.1	Monthly Average Electricity Load Demand in 2016	17
Figure 2.2	Monthly Peak Load Demand in 2016	18
Figure 2.3	Typical Daily Load Demand Profile in 2016	18
Figure 2.4	Belingus Power Station Typical Load Demand in 2016	24
Figure 2.5	Daily Electricity Demand Comparison of Eco Township Development vs Normal Development	25
Figure 2.6	Monthly Electricity Demand for Normal Township Development (Forecast for January–December 2025)	26
Figure 2.7	Monthly Electricity Demand for Eco Township Development (Forecast for January–December 2025)	26
Figure 2.8	Projected Daily Load Profile in January 2025 for Normal Township Development	27
Figure 2.9	Projected Daily Load Profile in January 2025 for Eco Township Development	28
Figure 2.10	Daily Electricity Load Demand Profile Showing Breakdowns and Total Demand for Normal Township Development	28
Figure 2.11	Daily Electricity Load Demand Profile Showing Breakdowns and Total Demand for Eco Township Development	29
Figure 3.1	Basic Concept of Simulation Model	30
Figure 3.2	Supply Electricity with D=12MW, PV= 24MW, Storage=78MWh for the Normal Demand	34
Figure 3.3	Supply Electricity with D=12MW, PV= 4.8MW, Storage=48MWh for the Eco Demand	34
Figure 3.4	Supply Electricity with D=6MW, PV=120MW, Storage=210MWh for the Normal Demand	35

Figure 3.5	Supply Electricity with D=6MW, PV=72MW, Storage=180MWh for the Eco Demand	35
Figure 3.6	Supply Electricity with D=0MW, PV=144MW, Storage=540MWh for the Normal Demand	36
Figure 3.7	Supply Electricity with D=0MW, PV=120MW, Storage=450MWh for the Eco Demand	36
Figure 3.8	Diesel Operation Rate at the Best Power Mix	40
Figure 3.9	Solar PV Load Factor at the Best Power Mix	40
Figure 3.10	Storage Operation Rate at the Best Power Mix	41
Figure 3.11	Initial Investment Cost at the Best Power Mix	42
Figure 3.12	Fuel Cost at the Best Power Mix	42
Figure 3.13	LCOE at the Best Power Mix	43